



INVITATION TO BID
VILLAGE HALL LED LIGHTING UPGRADE
ADDENDUM NO. 2
SEPTEMBER 13, 2023

1. IMPORTANT INSTRUCTIONS TO BIDDERS

This addendum must be read, signed, and dated by the firm and included with the documents submitted by the firm on or before proposal closing date and time. Failure to include this addendum with the documents may result rejection of proposal.

2. QUESTIONS:

Q: Per the addendum the Lobby light fixtures are to be replaced with new fixtures. Also, per the addendum all emergency ballast fixtures are to be replaced with just new bulbs. At least two of the fixtures in the lobby have emergency ballasts. Are those to be swapped with new fixtures with emergency drivers?

A: Yes, the lobby fixtures that have emergency ballasts should be replaced with new fixtures that have the same function.

3. ACKNOWLEDGMENT

The firm acknowledges receipt of this Addendum and understands its content to the Request for Proposal Documents.

4. SIGNATURE AND DATE

Authorized Signature

Date