



INVITATION TO BID  
WELL, PRV AND BOOSTER SITE LED LIGHTING  
UPGRADE  
ADDENDUM NO. 1  
July 26, 2024

1. IMPORTANT INSTRUCTIONS TO BIDDERS

This addendum must be read, signed, and dated by the firm and included with the documents submitted by the firm on or before proposal closing date and time. Failure to include this addendum with the documents may result rejection of proposal.

2. ATTACHMENTS TO THIS ADDENDUM:

- a. Revised 7/26/24 Exhibit B - Original lighting drawings and fixture schedule. All contractors are required to field verify the fixture and bulb types and quantities.

3. QUESTIONS:

**Q:** What are the hours of operation for each facility?

**A:** Monday through Friday 7:00am – 3:00pm. Saturdays and Sundays 2 hours each. The wells operate 24/7, but the lights are only used when an operator is onsite.

4. ACKNOWLEDGMENT

The firm acknowledges receipt of this Addendum and understands its content to the Request for Proposal Documents.

6. SIGNATURE AND DATE

---

Authorized Signature

Date

**Village of Oswego Estimated Wells, Booster Station, and PRV Light Fixture Inventory**  
**Contractor is Responsible to Verify Quantities**

<b>Well 3</b>	Qty	Size	Voltage	Fixture Type	Bulb Type	Bulbs Per Fixture
340 S. Madison	4	4 ft.	120	T8	F32T8/TL735	2
	10	8 ft.	120	T12	F96T12/CW/HO/EW	2

<b>Well 4</b>	Qty	Size	Voltage	Fixture	Bulb Type	Bulbs Per Fixture
401 Chicago Road	1	4 ft.	120	T8	F32T8/TL735	2
	3	4ft.			LED	
	8	8 ft.	120	T12	F96T12/CW/HO/EW	2

<b>Well 6</b>	Qty	Size	Voltage	Fixture	Bulb Type	Bulbs Per Fixture
245 Lennox Drive	1	4 ft.	120	T8	F32T8/TL735	2
	2	4 ft.	120	T8	F40 Universal	2
	2	4 ft.	120	T8	F40 Universal	4
	7	8 ft.	120	T12	F96T12/CW/HO/EW	2
	2				Down Lights	1

Replace each with 4' Vapor LED  
 Replace each with 4' Vapor LED  
 Replace with (1) 4' vapor LED

<b>Well 7</b>	Qty	Size	Voltage	Fixture	Bulb Type	Bulbs Per Fixture
378 Ogden Falls Blvd	13	4 ft.	120	T8	F32T8/SP35	2
	8	8 ft.	120	T12	F96T12/CW/HO/EW	2

<b>Well 8</b>	Qty	Size	Voltage	Fixture Type	Bulb Type	Bulbs Per Fixture
3700 Grove Road	12	4 ft.	120	T8	F32T8/Daylight	2
	7	8 ft.	120	T12	F96T12/CW/HO/EW	2

<b>Well 9</b>	Qty	Size	Voltage	Fixture Type	Bulb Type	Bulbs Per Fixture
700 Yoakum Blvd	17	4 ft.	120	T8	F32T8/735/Eco	2
	5	High Bay	120	Metal Halide	MVR250/VBU/PA	1

Scaffolding Needed

<b>Well 10</b>	Qty	Size	Voltage	Fixture Type	Bulb Type	Bulbs Per Fixture
700 Cole Avenue	17	4 ft.	120	T8	F32T8/TL941	2
	6	High Bay	120	Metal Halide	MVR250/VBU/PA	1

Scaffolding Needed

<b>Well 11</b>	Qty	Size	Voltage	Fixture Type	Bulb Type	Bulbs Per Fixture
3701 Tuscany Trail	15	4 ft.	120	T8	F32T8/SP35/ECO	2
	6	High Bay	120	LED	???	1

Scaffolding Needed

<b>PRV 4</b>	Qty	Size	Voltage	Fixture	Bulb Type	Bulbs Per Fixture
244 Washington Street	1	4 ft.		T8	F32T8/SP30	2

<b>PRV 5</b>	Qty	Size	Voltage	Fixture	Bulb Type	Bulbs Per Fixture
Rt 71 / 1 Forest Avenue	1	4 ft.		T8	F32T8/SP30	2

<b>Booster 2</b>	Qty	Size	Voltage	Fixture	Bulb Type	Bulbs Per Fixture
1613 Rt 34	4	4 ft		T8	F40CW/SS	2

**Estimated Totals**

4' T8	8' T8	Metal Halide	High Bay LED
91 or 94	39	11	6